

CERTIFICATE OF COMPLIANCE

Certificate Number 20141216 – R26421
Report Reference R26421 - 20070508
Issue Date 2014-DECEMBER-16

Issued to: ASTURMADI S L
Applicant Company: Poligono De Las Arobias
Travesia De La Industria 51
33401 Aviles, SPAIN

Listed Company: PUERTAS ASTURMEX S A DE C V
CALLE NORTE 45 NO 686
COL INDUSTRIAL VALLEJO
AZCAPOTZALCO
DF
02300

This is to certify that representative samples of Special-purpose Fire Doors
USL - Asturmadi model Firestop 180UL Swing type fire door and frame assembly intended for 3 hr applications. The assembly consists of a single door leaf with frame and hardware intended for use in masonry constructions.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10B, "Fire Tests of Door Assemblies."
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

